





Electrical Rating **230V**

Power:230VAC
Consumption:2w
IP Rating: IP54

Assembly




Disassembly




NC - NORMALLY CLOSED

OPTIONAL

Testing - Fit actuator to base.
Apply power for six minutes.
Allow to cool.




After testing, check correct adaptor has been fitted, using images below.



230V

Normal Operation



Room

Heating Circuit No.

